

Heat Pump 21-Point Precision Tune-Up and Professional Cleaning Includes:

- 1. _____Clean filters as needed
- 2. _____Clean debris from around the outdoor condenser
- 3. _____Clean Condenser coil and remove debris
- 4. _____Clean indoor evaporator coil if accessible
- 5. _____Visually Inspect condenser coil
- 6. _____Monitor volts/amps on fan motor
- 7. _____Lubricate and inspect bearings for wear
- 8. _____Flush and treat condensate drain with anti-algae
- 9. _____Monitor operating pressure of refrigerant
- 10._____Monitor compressor for proper amperage, volt draw and all wiring connections
- 11._____Inspect safety devices for proper operation
- 12.____Inspect electrical system for exposed wiring
- 13.____Inspect fan blades
- 14._____Visually Inspect duct work for energy loss
- 15._____Measure temperature for difference of supply & return ducts
- 16._____Inspect service valves for proper operation
- 17._____Inspect disconnect box for proper rating and installation
- 18._____Tighten all electrical connections as needed
- 19._____Test and inspect capacitors
- 20._____Test and inspect contactors for burned or pitted contacts
- 21.____Check operation of the thermostat

Your Comfort Plus service Technician performed a complete 21-Point precision tune-up and professional cleaning of your Heat Pump that took______ of time to complete. Your Air Conditioner is inspected and adjusted to the optimum performance.

Recommendations:

Date of inspection & cleaning _____

"Your Trusted Source for HVAC"